

Do not scale off this drawing. All dimensions to be checked on site prior to manufacture and construction. This drawing is the property of JH Architects and should not be reproduced without permission. All discrepancies to be brought to the attention of the architect immediately. This drawing to be read in conjunction with the specification / bill of quantities and related drawings.

REVISION	DESCRIPTION	DATE	BY
-	FIRST ISSUE	05.07.24	PM



FIRE AUTHORITY REQUIREMENTS	
F30 HALF HOUR FIRE RESISTANT WITH SMOKE SEALS & INTUMESCENT STRIPS	ⓔ AREA COVERED BY MAINTAINED EMERGENCY LIGHT FITTING TO BS 5266 PART 1
F60 ONE HOUR FIRE RESISTANT WITH SMOKE SEALS & INTUMESCENT STRIPS	Ⓜ AREA COVERED BY SMOKE DETECTORS
VP VISION PANEL	Ⓜ FIRE ALARM CALL POINT
PB PANIC BOLT	Ⓜ FIRE ALARM INDICATOR PANEL
SC SELF-CLOSING	Ⓜ FIRE ALARM CALL POINT
SCA SELF-CLOSING AUTOMATIC RELEASE	Ⓜ FIRE ALARM CALL POINT
FL FUSIBLE LINK	Ⓜ FIRE ALARM CALL POINT
DS DOOR SELECTOR	Ⓜ FIRE ALARM CALL POINT
EXIT SELF CONTAINED MAINTAINED DIRECTIONAL EMERGENCY EXIT SIGN ILLUMINATED SUSPENDED *FIRE EXIT SIGN 75mm LETTERS	Ⓜ FIRE ALARM CALL POINT
S13 *FIRE DOOR KEEP SHUT* 10mm LETTERS TO BOTH SIDES OF DOOR LEAF	Ⓜ FIRE ALARM CALL POINT
S14 *FIRE DOOR KEEP LOCKED* 10mm LETTERS TO BOTH SIDES OF DOOR LEAF	Ⓜ FIRE ALARM CALL POINT
S20 *FIRE ESCAPE KEEP CLEAR* 10mm LETTERS TO BOTH SIDES OF DOOR LEAF	Ⓜ FIRE ALARM CALL POINT
S22 *FIRE EXIT* 20mm LETTERS	Ⓜ FIRE ALARM CALL POINT
S25 *PUSH BAR TO OPEN* 20mm LETTERS	Ⓜ FIRE ALARM CALL POINT
S26 DIRECTIONAL ARROW (GREEN)	Ⓜ FIRE ALARM CALL POINT
FRG FIRE RESISTING GLAZING ELEMENT	Ⓜ FIRE ALARM CALL POINT
	Ⓜ AREA COVERED BY HEAT DETECTORS
	Ⓜ FIRE ALARM CALL POINT
	Ⓜ FIRE ALARM INDICATOR PANEL
	Ⓜ FIRE BLANKET IN CONTAINER
	Ⓜ CARBON DIOXIDE FIRE EXTINGUISHER
	Ⓜ 9 LITRE WATER EXTINGUISHER
	Ⓜ DRY POWDER EXTINGUISHER
	Ⓜ FOAM FIRE EXTINGUISHER
	Ⓜ ALARM WARNING DEVICE (voice type in Customer Areas) music sound system to be de-activated
	KEY
	Ⓜ AREA FOR THE SALE OF ALCOHOL, PROVISION OF NIGHT REFRESHMENT AND REGULATED ENTERTAINMENT

CLIENT	JD WETHERSPOON
PROJECT	LONDON BRIDGE STATION TOOLEY STREET, SE1 9SG
TITLE	PROPOSED LICENSING PLAN
JOB NO.	JDW109
DWG NO.	AL9.01
SCALE	1:100 @ A2
DRAWN	PM

46 MANCHESTER ROAD
CHORLTON
MANCHESTER
M21 9PH
info@justharchitects.co.uk
T +44(0)161 237 5500



POWER
SUPPLY
FIRE PANELS
WATER